SECTION 905 -- PROPOSAL (CONTINUED)

I (We) hereby certify by digital signature and electronic submission via Bid Express of the Section 905 proposal below, that all certifications, disclosures and affidavits incorporated herein are deemed to be duly executed in the aggregate, fully enforceable and binding upon delivery of the bid proposal. I (We) further acknowledge that this certification shall not extend to the bid bond or alternate security which must be separately executed for the benefit of the Commission. This signature does not cure deficiencies in any required certifications, disclosures and/or affidavits. I (We) also acknowledge the right of the Commission to require full and final execution on any certification, disclosure or affidavit contained in the proposal at the Commission's election upon award. Failure to so execute at the Commission's request within the time allowed in the Standard Specifications for execution of all contract documents will result in forfeiture of the bid bond or alternate security.

Bidder acknowledges receipt of and has added to and made a part of the proposal and contract documents the following addendum (addenda):

ADDENDUM NO. ADDENDUM NO		DATED <u>2/1</u> DATED	5/2022	ADDENDUM NO ADDENDUM NO.	DATED DATED		
ADDENDUM NO		DATED		ADDENDUM NO.	DATED		
Number 1 Revised Table of Co 718-1; Amendment E			& 907-	ADDRESS	Contractor Signature		
				CITY, STATE, ZIP PHONE			
				FAX			
(To be filled in if a corpo	ration)		2	E-MAIL			
Our corporation is charter titles and business addres	red under the La					_ and the	names,
Pr	resident				Address		
Se	ecretary				Address		
Tr	easurer				Address		
The following is my (our) STP-0037-04(063 Yazoo County(ie Revised 01/26/2016	3)/ 107954301						

MISSISSIPPI DEPARTMENT OF TRANSPORTATION TABLE OF CONTENTS

PROJECT: STP-0037-04(063)/107954301 - Yazoo

Section 901 - Advertisement

Section 904 - Notice	to Bidders			
#1	Governing Specification, w/ Supplement			
#2	Status of ROW, w/ Attachments			
#3	Final Cleanup			
#9	Federal Bridge Formula			
#13	Safety Edge			
#113	Tack Coat			
#296	Reduced Speed Limit Signs			
#445	Mississippi Agent or Qualified Nonresident Agent			
#516	Errata and Modifications to the 2017 Standard Specifications			
#977	DUNS Requirement For Federal Funded Projects			
#1225	Early Notice to Proceed			
#1226	Material Storage Under Bridges			
#1241	Fuel and Material Adjustments			
#2206	MASH Compliant Devices			
#2273	Mississippi Special Fuel Tax Law			
#2611	Disadvantaged Business Enterprise In Federal-Aid Highway Construction, w/			
	Supplement			
#2782	DBE Pre-Bid Meeting			
#2954	Reflective Sheeting for Signs			
#3599	Standard Drawings w/Supplement			
#3676	Asphalt Gyratory Compactor Internal Angle Calibration			
#3827	Contract Time			
#3828	Specialty Items			
#3829	Scope of Work			
906	Required Federal Contract Provisions FHWA 1273, w/Supplements			
Section 907 - Special	Provisions			
907-102-2	Bidding Requirements and Conditions			
907-105-1	Authority of the Engineer			
907-108-4	Subletting of Contract			
907-109-3	Measurement and Payment			
907-618-4	Additional Signing Requirements, w/Supplement			
907-619-6	Temporary Portable Rumble Strips			
907-701-3	Hydraulic Cement			
907-702-4	Bituminous Materials			
907-703-1	Gradation			
907-705-1	Stone Riprap			
907-707-3	Joint Materials			
907-711-2	Plain Steel Wire			
907-712-1	Fence and Guardrail			
907-714-3	Miscellaneous Materials			

PROJECT: STP-0037-04(063)/107954301 - Yazoo

907-718-1Timber and Dimension Lumber907-720-2Acceptance Procedure for Glass Beads907-721-2Materials for Signs

Section 905 - Proposal, Proposal Bid Items, Combination Bid Proposal Certification of Performance - Prior Federal-Aid Contracts Certification Regarding Non-Collusion, Debarment and Suspension SAM.GOV Registration and DUNS Number Section 902 - Contract Form Section 903 - Contract Bond Forms Form -- OCR-485

Progress Schedule

(REVISIONS TO THE ABOVE WILL BE INDICATED ON THE SECOND SHEET OF SECTION 905 AS ADDENDA) 02/15/2022 09:00 AM

MISSISSIPPI DEPARTMENT OF TRANSPORTATION

SPECIAL PROVISION NO. 907-712-1

CODE: (SP)

DATE: 12/07/2021

SUBJECT: Fence and Guardrail

Section 712, Fence and Guardrail, of the 2017 Edition of the Mississippi Standard Specifications for Road and Bridge Construction is hereby amended as follows.

907-712.01--General. After the sentence in Subsection 712.01 on page 785, add the following.

All materials' inspection, testing, and certification will be performed in accordance with the requirements of the current version of the Department's *Materials Division Inspection, Testing, and Certification Manual*.

Delete Subsections 712.02 and 712.03 on page 785, and substitute the following.

<u>907-712.02--Barbed Wire.</u> Barbed wire shall conform to the requirements of AASHTO M 280. In the coastal counties of Hancock, Harrison, and Jackson, either Coating Type Z Class 3 or Coating Type A shall be furnished. In all other areas of the State, either Coating Type Z Class 1, Coating Type Z Class 3, Coating Type ZA Class 60, or Coating Type A shall be furnished.

<u>907-712.03--Metallic-Coated, Steel Woven Wire Fence Fabric</u>. Woven wire fencing (i.e., "hog wire") shall conform to the requirements of AASHTO M 279. In the coastal counties of Hancock, Harrison, and Jackson, either Coating Type Z Class 3 or Coating Type A shall be furnished. In all other areas of the State, either Coating Type Z Class 1, Coating Type Z Class 3, Coating Type ZA Class 60, or Coating Type A shall be furnished.

<u>907-712.04--Chain Link Fence.</u> Delete Subsections 712.04.1 thru 712.04.7 on pages 785 & 786, and substitute the following.

<u>907-712.04.1--Fabric.</u> In the coastal counties of Hancock, Harrison, and Jackson, either Type I Class D, Type II, Type III, or Type IV fabrics shall be furnished. In all other areas of the State, either Type I Class C, Type I Class D, Type II, Type III, or Type IV fabrics shall be furnished.

<u>907-712.04.2--Tie Wire</u>. Tie wire shall be of the same material as the fencing wire being used, shall be of good commercial quality, and shall meet the requirements of AASHTO M 181. Either Type I, Type II, or Type IV tie wire shall be furnished.

<u>907-712.04.3--Tension Wire.</u> Tension wire shall be of the same material as the fencing wire being used, shall be of good commercial quality, and shall meet the requirements of AASHTO M 181. In the coastal counties of Hancock, Harrison, and Jackson, either Type I Class 3, Type II, Type III, or Type IV tension shall be furnished. In all other areas of the State, either Type II, Type III, Type IV, or Type I Classes 1, 2, or 3 tension wires shall be furnished.

<u>907-712.04.4--Posts Rails, Gate Frames, and Expansion Sleeves.</u> Posts, rails, gate frames, and expansion sleeves shall conform to the requirements for posts in Subsection 712.05.2, unless otherwise designated in the contract.

<u>907-712.04.5--Miscellaneous Fittings and Hardware.</u> Miscellaneous fittings and hardware shall conform to the requirements of Subsection 712.16.

907-712.05--Fence Posts and Braces.

907-712.05.1--Treated Timber Posts and Braces.

<u>907-712.05.1.1--General.</u> Delete the third, fourth, fifth, and sixth paragraphs of Subsection 712.05.1.1 on page 787, and substitute the following.

All wood posts and braces shall be treated in accordance with Subsections 718.03 and 718.04.

<u>907-712.05.1.2--Round Posts</u>. Delete the last sentence of the last paragraph of Subsection 712.05.1.2 on page 788.

<u>907-712.05.1.3--Sawed Posts.</u> Delete the last sentence of the paragraph of Subsection 712.05.1.3 on page 788.

<u>907-712.05.1.4--Sawed Braces.</u> Delete the last sentence of the paragraph of Subsection 712.05.1.4 on page 788.

Delete Subsection 712.05.2 on page 788, and substitute the following.

907-712.05.2--Metal Posts.

<u>907-712.05.2.1--Round Steel Pipe.</u> Round steel pipe shall meet the requirements of AASHTO M 181, either Grade 1 (i.e., meeting the requirements in ASTM F 1083) or Grade 2 (i.e., meeting the requirements of ASTM F 1043).

Round steel pipe shall be sized in accordance with NPS (nominal pipe size) designations as shown on Plans, and not according to the outer or inner pipe diameter.

<u>907-712.05.2.2--Steel Fence Post and Assemblies, Hot-Wrought</u>. Steel posts with the following section shapes, Tee, channel or U, and Y-Bar shall meet the requirements of AASHTO M 281, galvanized in accordance with the requirements of AASHTO M 111, unless otherwise specified in the contract. Acceptance of these steel posts shall be by certification from the manufacturer, producer, supplier, or fabricator, as applicable.

907-712.05.2.3--Blank.

<u>907-712.05.2.4--Steel H-Beam Posts.</u> Steel H-Beam posts shall be produced from structural quality weldable steel having a minimum yield strength of 45,000 psi and shall be galvanized in accordance with ASTM A 123. Steel H-Beam line posts shall be 2.250 inches by 1.625 inches and shall weigh 3.43 pounds per foot. A tolerance of plus or minus 5.0 percent is allowed for

weight per foot. A tolerance of plus or minus 1.0 percent is allowed for dimensions.

<u>907-712.05.2.5--Aluminum-Alloy Posts and Assemblies.</u> Round aluminum-alloy posts shall meet the requirements of ASTM B 241, Alloy 6061, T6. Aluminum-Alloy H-Beam posts shall meet the requirements of ASTM B 221, Alloy 6061, T6.

<u>907-712.05.2.6--Formed Steel Section Posts.</u> Formed steel section posts, "C" sections, shall be formed from sheet steel conforming to ASTM A 1011, Grade 45, and shall be galvanized in accordance with ASTM A 123.

907-712.06--Guard and Guardrail Posts.

907-712.06.2--Treated Wood Posts.

<u>907-712.06.2.1--Square Posts.</u> Delete the paragraph in Subsection 712.06.2.1 on page 789, and substitute the following.

All square posts shall be inspected for conformance with Section 712.05, except that the posts may be rough and shall be within $\pm 3/8$ " of the dimensions shown on the plans.

<u>907-712.06.2.2--Round Posts.</u> Delete the paragraph in Subsection 712.06.2.2 on page 789, and substitute the following.

All round posts shall be inspected for conformance with Section 712.05, except that the posts shall be of the shape and dimensions shown on the plans.

<u>907-712.06.5--Treated Wood Blocks for Use with Metal Guardrail Posts.</u> Delete the paragraphs of Subsection 712.06.5 on pages 789 & 790, and substitute the following.

Treated wood blocks for use with metal guardrail posts shall be within $\pm 3/8$ " of the size and dimensions shown on the plans, except that a minus tolerance shall not be allowed for the slotted width in which the metal post must fit.

Delete Subsection 712.16 on page 791, and substitute the following.

<u>907-712.16--Hardware</u>. All ferrous metal hardware for fencing such as bolts, nuts, washers, and metal straps shall be as specified on the plans and galvanizing shall not be less than 1.0 ounce per square foot of uncoated area. Aluminum coated hardware shall be coated with aluminum meeting the requirements of AASHTO M 181 for aluminum coating and at the rate of not less than 0.4 ounces per square foot of uncoated area.

Aluminum alloy hardware shall conform to the requirements of ASTM B 221 for extruded aluminum alloy 6063, T6. The finished members shall be of uniform quality.

Aluminum-zinc coated hardware shall be coated with an aluminum-zinc alloy meeting the chemical requirements and weight of coating specified for aluminum-zinc alloy coated metal gates.

MISSISSIPPI DEPARTMENT OF TRANSPORTATION

SPECIAL PROVISION NO. 907-718-1

CODE: (SP)

DATE: 12/07/2021

SUBJECT: Timber and Dimension Lumber

Section 718, Timber and Dimension Lumber, of the 2017 Edition of the Mississippi Standard Specifications for Road and Bridge Construction is hereby amended as follows.

Delete the Subsections in Section 718 on pages 836 thru 838, and substitute the following.

<u>907-718.01--General.</u> All timber and dimension lumber shall be Southern pine and shall conform in all respects to applicable requirements of AASHTO M 168. The Department reserves the right to sample and to test all materials at any time; all inspection, testing, and certification of materials will be performed in accordance with the requirements of the current version of the Department's *Materials Division Inspection, Testing, and Certification Manual*.

Timber and dimension lumber shall be furnished in the sizes shown on the plans or as specified. Unless otherwise specified, timber and dimension lumber shall be No. 1, or better, graded according to the latest American Lumber Standards.

Only one type of preservative shall be used for the treatment of materials for any one class of construction on a project, unless otherwise specified.

Where treated timber and dimensional lumber is to be used in non-highway construction or use, such as decking, handrails in walking trails, or in any manner where general public exposure by touch is possible, the treatment requirements will be as per project plans and/or approved by the State Materials Engineer.

<u>907-718.02--Untreated Timber and Dimension Lumber</u>. Untreated timber and dimension lumber shall conform to the requirements of AASHTO M 168.

<u>907-718.03--Treated Timber and Dimension Lumber</u>. Timber and dimension lumber to be treated shall meet the requirements herein specified and shall be treated as specified. Treated timber or dimensional lumber will not be accepted for use unless it has been inspected by an authorized representative of the Department and found to be satisfactory after treatment.

907-718.03.1--Blank.

<u>907-718.03.2--Treatment.</u>

<u>907-718.03.2.1--General.</u> All materials shall be treated in accordance with AASHTO M 133 unless otherwise directed by the Environmental Protection Agency (EPA).

907-718.03.2.2--Blank.

<u>907-718.03.2.3--Inspection</u>. Treated timber and dimension lumber shall be inspected by an authorized representative of the Department before being incorporated into the work. Treatment reports shall be provided to the Department for each lot of material supplied.

907-718.03.3--Blank.

<u>907-718.03.4--Storage of Treated Material</u>. All material treated for stock shall be stacked as compactly as possible on a well-drained surface. Material shall be supported on sills spaced as necessary, not to exceed 10 foot intervals and shall have at least one foot of air space beneath the stacks.

All materials treated with preservatives for use in buildings and applications where painting is required shall be dried after treatment. The treated wood shall be dried in accordance with American Lumber Standards.

<u>907-718.04--Preservative</u>. Preservatives shall be as specified in AASHTO M 133 unless otherwise directed by the Environmental Protection Agency (EPA).