

**Call 14 Intersection Improvements on various routes throughout the District, known as Federal Aid Project No. HSIP-9999-03(017) / 107793301 in District 3.**

Q1. Will MDOT consider changing the specialty items list to make it possible for an electrical contractor to bid as prime and not have to control 40% of the contract?

A1. No.

Q2. Can a polymer concrete box be used for Pay Item 682-E002 Underground Junction Box?

A2. Yes.