

Call 04 Mill & Overlay approximately 8 miles of SR 15 from north of CR 561 to the Winston County Line, known as Federal Aid Project No. HSIP-0022-02(073) / 109143301 in Neshoba County.

Q1. 1.) Can we get a typical section issued for the concrete paving sections that shows rebar size and spacing? 2.) What kind of material will be used under the concrete paving section?

A1. 1.) Standard Drawing CRP-1 will be used and modified to fit field conditions with approval by the Engineer. 2.) It is anticipated that concrete pavement will be placed directly on the original base.