

Call 06 Bridge Replacement on SR 27 over Little White Oak Creek (Bridge No. 93.1), known as Federal Aid Project Nos. BR-0054-02(025) / 106113302 & 303 in Covich & Hinds Counties.

Q1. What will 403-B004 19-mm, HT, Asphalt Pavement Leveling be used for?

A1. ~~The intent is to level the roadway where the existing pavement is to remain as shown on Working No. TS-1, Sheet No. 6 (bottom typical section).~~ **Revised Answer:** See addendum.

Q2. Ref: sheet 8015 the drawing calls for the prefabricated deck drains to be HSS 8 x 3 x 3/8 material. On past jobs, the material has always been 3/16" thick. Is 3/8" the correct thickness? The 3/8 material cost is over twice the price even though this is a small amount.

A2. 3/16" is correct.