

**Call 03 Emergency Slide Repair on US 80 in Forest, known as Federal Aid Project No. STBG-2904-00(020) / 109631301 in Scott County.**

- Q1. 1.) Will MDOT be able to provide benchmarks for grade control? 2.) Is there a digital topo profile of the site available for construction use? 3.) Note 24 of plan sheet #4 states that "At no time shall the contractor be allowed to work within the KCS Railroads right-of-way." If this is correct, is there any need for any costs associated with Bid Item #907-899-A001 "Railway Highway Provisions" and associated specification section requirements to be included in this project?
- A1. 1.) This information will be provided to the successful bidder. 2.) This information will be provided to the successful bidder. 3.) Bidders are advised to bid as per the plans due to the possibility of the Contractor's equipment fouling the tracks.
- Q2. 626.03.3 Retroreflectivity Requirements Will retroreflectivity measurements be required the striping on this project as the quantity is less than the one mile segment minimum referenced in the specification?
- A2. No, measurements will not be required for this project.