

Call 11 Overlay approximately 6 miles of SR 35 from SR 18 to SR 481, known as State Project No. SP-0023-01(096) / 109046301 in Smith County.

- Q1. Pay Item 304-D002 has Granular Material, Crushed Stone shown and the typical section on page 63 shows Granular Material CL. 6 Gr. D. What material is to be placed on the shoulders?
- A1. Bidders are advised that any reference to Granular Material, Cl 6 Gr D is in error and shall be understood to be Granular Material, Crushed Stone. The bid sheets are correct.