

Call 06 Bridge Replacement on SR 481 between SR 902 & SR 35 (Bridge Nos. 2.1 & 2.3), known as Federal Aid Project No. BR-0331-00(013) / 107851301 in Smith County.

Q1. Will the contractor be allowed to work on phase 1 (Bridge Site) and phase 2 (Box Site) at the same time?

A1. See Addendum 1.

Q2. Pay item # 202-A001 Removal of Obstruction is shown in the proposal but not on the plans. The proposal references some fencing and gates to be removed under this item but pay item # 202-B126 Removal of Fence, All Types is also given. Should one of these pay items be removed?

A2. See Addendum 1.

Q3. Will MDOT add a pay item for Select Material for Undercuts, Contractor Furnished (206-B001) or should the contractor just absorb this item?

A3. See Addendum 1.

Q4. In reference to Note #3 on Sheet 11, does the clearing debris to be mulched on site include large tree trunks or just the limbs and small trees? Can clearing debris be hauled off in lieu of mulched on site?

A4. The clearing included will consist primarily of limbs, small trees, and brush within the area of the repair and pile driving as needed. A small number of select trees (larger than 4" for reference) may need to be removed depending on equipment size used to perform the slope repairs though it is not anticipated. The intent is not to clear ROW to ROW. The cleared material may be mulched on site or hauled away at the Contractor's option.