

Call 13 Mill & Overlay approximately 3 miles of MS 487 from east of Tuscolameta Big Canal to SR 35, known as State Project No. MP-5487-40(016) / 309962301 in Leake County.

Q1. 1.) What is the depth of the 12.5mm leveling asphalt required for repair of the failed areas listed on page 66 of proposal? 2.) Will local road intersections and driveway pads be paved with both the leveling and final 2" lift?

A1. 1.) The depth of the leveling for failed area repair varies from 5 inches to 3 feet. 2.) The local road intersections and driveway pads will be paved with both the leveling lift and the 2" surface lift.

Q2. In the Special Provision 907-401-3 of the proposal, Section 907-401.03.1.2 Tack Coat section does not discuss the other options on tack coats that are not on the approved product list like the Special Provision normally does. Those products are CSS-1, CSS-1H, SS-1, and SS1-h. Will those products be allowed for this project?

A2. No.