

Call 08 Bridge Repair on SR 16/SR 149 over SR 3 & Yazoo River (Bridge No. 203.3), known as Federal Aid Project No. STBG-0091-01(009) / 108865301 in Yazoo County.

Q1. Can you provide as-built plans for the existing caps #13-#16 and spans #13-#15 including the detail of the existing girders?

A1. As-built plans can be downloaded at the following link: <https://file-exchange.mdot.state.ms.us/dl/?f=6957783733ebf28d299bbb0529e15190b14fe904>

Q2. Plan sheet 8004 has details showing slab repairs on joint halves for Span 12 & 16. Plan sheet 8005 has details showing the same repairs. Can MDOT please confirm which repair is correct.

A2. Sheet 8004 has the correct details for the blackout repair for spans 12 & 16. 8005 is a standard sheet showing the replacement of the existing finger joint with a preformed joint seal. Sheet 8005 does not exactly correspond to the scope for this scenario as the blackout repair area will be the full depth of the deck. In instances where there is a conflict, Sheet 8004 shall govern.

Q3. Could MDOT provide a link to the as-built bridge plans for this project?

A3. See Answer 1.