

Call 11 Building Improvements at MDOT Parking Garage Downtown, known as State Project No. BWO-9021-25(021) / 503889301 in Hinds County.

Q1. Looking to sub parking lot striping

A1. That is the responsibility of the Contractor. Below are links to the Vendor List published on the MDOT website and the MS State Board of Contractors.

https://mdot.ms.gov/portal/vendor_list

https://search.msdoc.us/?_gl=1*c36ott*_gcl_au*MTA4MzA2Mjg2NS4xNzc5Mzc4OTM4

Q2. Is the Traffic Deck Coating being installed on the walkways for lvls 5, 5.5 and 6?

A2. The traffic deck coating will cover the topside of the deck including raised concrete islands/walkways and will extend 6-inches up the interior side of the walls. Additionally, the traffic deck coating will terminate at the exterior side of the doorway to the stairwells and elevator. This includes but is not limited to levels 5, 5.5 and 6.

Q3. Are there liquidated damages and retainage for this project?

A3. Yes, there are liquidated damages. No, there is not retainage.